

FORM -C

(Form of Certificate of structural soundness under sub-section (4) of Section 4 of the Tamilnadu Public Buildings (Licensing) Act, 1965 (Tamilnadu Act, 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules, 1966)

1. Foundation Depth below.

Ground level	..	2.9 meter
Nature of soil met with at foundation level	..	Hard Gravel with rock.
Probable safe bearing capacity of the statement with at foundation	..	200 KN/m ² .
Pressure at foundation	..	300 KN/m ² .

2. Superstructure

Maximum stress in the most critical section of masonry and concrete	..	RCC column footing 1:1.5:3 - 370 KN/sq m
Nature of masonry and concrete and its safe permissible stresses	..	Brick in CM 60 KN/sq m RCC M20 mix -5N/sq mm

I have satisfied that the buildings are structurally sound to be used as public buildings for the purpose specified in the statement.

The structural soundness of the buildings has been verified taking in account ISI loading standard 875 latest version and other relevant Indian standard code of practice and I declare the building are structurally sound to be used as a public building for the purpose noted in the statement.

It is certified that the **Maharishi International School** constructed has been designed for the above mentioned loads and seismic loads as per relevant codes specified by Bureau of Indian Standards 3Years (02.05.2019 to 01.05.2022).

Place: Coimbatore

Date : 02.05.2019.

Signature of the Engineer.



FORM - B

(Form of Certificate of structural soundness under sub-section (4) of Section 4 of the Tamilnadu Public Buildings (Licensing) Act, 1965 (Tamilnadu Act, 13 of 1965) referred to in rule 4 of the Tamilnadu Public buildings (Licensing) Rules 1966)

Place : Coimbatore

Date : 02.05.2019.

Signature of the Engineer.




STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

- | | | | |
|----|--|----|--|
| 1. | Location of the building door
Number Street and name of the Place
Town Panchayat of Coimbatore | .. | S.F.No:30/7,
Zamin Muthur Village,
Pollachi Taluk,
Coimbatore Dist. |
| 2. | Age of the building | .. | 2,yrs above . |
| 3. | Purpose for which the building can be used | .. | School Purpose. |
| 4. | The period for which the building will be structurally sound: | .. | 3 years .
(02.05.2019 to 01.05.2022). |
| 5. | Number of persons to be accommodated | .. | 1200 Students + Teaching Staff
+ Non Teaching Staff |
| 6. | Remarks | .. | Good |

Place : Coimbatore

Date : 02.05.2019.

Signature of the Engineer



M. RAJASUBRAMANIAM MC(Struct)

Proceedings of the District Collector, Coimbatore.
Present : Thiru.T.N.Hariharan, I.A.S.,

Ref.No.7194/2017/C2

Dated: 01.09.2017.

Sub : Tamil Nadu Public Building Licensing act 1965 - Upgradation of the name of Thiru.M.Balasubramaniam in the panel of private practicing engineers from CLASS I to CLASS IA category in Coimbatore district - approval of the board of engineers - orders issued -reg

- Ref: 1. Superintending Engineer, PWD Buildings(C&M), Coimbatore
Lr.No.DB/DO2/F1142/119M/2017 dated.25.05.2017.
2. Engineer-In-Chief (Buildings),Chief Engineer(Buildings)
Chennai Region and Chief Engineer(General), PWD, Chennai
Lr.no.AEE/T1/AE/21124/2017 dated: 11.08.2017.

ORDER-

The Engineer-In-Chief (Buildings),Chief Engineer(Buildings) Chennai Region and Chief Engineer(General), PWD, Chennai in the reference 2nd cited has stated that the Board of Engineering Meeting resolved and approved the name of Thiru.M.Balasubramaniam (D.O.B.-06.05.1971) for inclusion and registering in the panel of Private Practicing Engineer from CLASS I to CLASS IA category (Buildings, the cost of which exceeds Rs.50 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated.17.02.2011) in Coimbatore District.

Accordingly, the Thiru.M.Balasubramaniam has been included in the panel of Private Practicing Engineer from CLASS I to CLASS IA category (Buildings, the cost of which exceeds Rs.50 lakhs) in Coimbatore district and entered the name against Sl.no. 05/2017 in the register of panel of Private Practicing Engineer maintained in this office.

Sd/-T.N.Hariharan
District Collector,
Coimbatore.

To

✓Thiru.M.Balasubramaniam,
103, 84A, Sarojini Complex,
Sengodu Kattur Street, P.N. Palayam.Coimbatore-641037

Copy to

1. Superintending Engineer, PWD Buildings(C&M), Coimbatore
2. Engineer-In-Chief (Buildings),Chief Engineer(Buildings) Chennai Region and Chief Engineer(General), PWD, Chepauk, Chennai

WATER SUPPLY REPORT

Report of Water Supply for the Maharishi International School S.F.No:30/7,
Zamin Muthur Village, Pollachi Taluk, Coimbatore Dist.

1. Maximum no. of persons to be accommodated .. 1200persons
2. Water requirement per person .. 45 litres / day
3. Max. water requirement for 1200 person .. 80 litres/day
4. Source for the above water requirement
 - a. From corporation water Inlet .. 1500 litres / day
 - b. From Borewell - 1no .. 14000 litres / day

Place : Coimbatore

Date : 02.05.2019.



R. Nagarajan

MAHARISHI INTERNATIONAL SCHOOL
Palakkad Road, Zamin Muthur,
Pollachi - 642 005.

R. Lalitha
PRINCIPAL

MAHARISHI INTERNATIONAL SCHOOL
Palakkad Road, Zamin Muthur,
POLLACHI - 642 005.

B. V. ...
M. BALASUBRAMANIAM, ME(Strsr).MIE
STRUCTURE & SOIL STABILITY BANK
COLLECTOR'S PANEL ENGINEER CL
103, 84-A, Sarojini Comple
Senkadu, Kattoor Street,
Near by Womens Polytechnic C
P.N. Palayam, Coimbatore - 64
Mobile No: 98432 65083

RAINWATER HARVESTING REPORT


Report of Rain Water Harvesting for the Maharishi International School
S.F.No:30/7, Zamin Muthur Village, Pollachi Taluk, Coimbatore Dist.

Place : Coimbatore

Date : 02.05.2019.



R. Nageswari
MAHARISHI INTERNATIONAL SCHOOL
Palakkad Road, Zamin Muthur,
Pollachi - 642 005.



M. BALASUBRAMANIAM, ME(Strsr), MIE.F.
STRUCTURE & SOIL STABILITY BANK V
COLLECTOR'S PANEL ENGINEER CLA
103, 84-A, Sarojini Complex
Senkadu, Kattoor Street,
Near by Womens Polytechnic Co
P.N. Palayama, Coimbatore - 641
Mobile No: 98432 65083

R. Lalitha
PRINCIPAL

MAHARISHI INTERNATIONAL SCHOOL
Palakkad Road, Zamin Muthur,
POLLACHI - 642 005.